

## Nova Medium 62 Trackspot

## Installation / Maintenance Instructions

### **LIGHT FORMS**





NOV62-TS

### Precautions and Warnings

- •Read all instructions carefully, the safety of this product is only guaranteed if the instructions are followed, retain these instructions for future use.
- •Turn off the power suppler before installation and maintenance.
- •Installation must be carried out be a trained professional in accordance with all National electrical codes and regulations.
- •To avoid the risk of fire and overheating, make sure all connection, including those made by others, are correct and secure.
- •Do not pinch or apply excessive tension on the electrical wires. Damage due to improper handling and installation will void the warranty.
- •If there is any damage to the product or the cable, the product must be returned to the retailer or manufacturer.





#### Luminaire Details

Power Supply:	230V AC 50Hz
IP Rating:	IP20
Class:	<b>(</b>
Ta Max:	45°C

Fixing Method:	Track adaptor	
Diameter:	62mm	
Length:	170mm	

**Light Forms**UK Head Office

LightForms.com

8 Richfield Avenue

Reading RG1 8EQ T +44(0)2085713785

E London@ LightForms.com


# Nova Small 62 Trackspot


# Installation / Maintenance Instructions

### **LIGHT FORMS**




Release locking tab.








Select the electrical circuit






In built driver

In-Track driver

Insert into track. Note the orientation and guide pins.









In-Track driver



Lock the fixture to the track.




In built driver



In-Track driver




Adjust.





Turn on power.



Light Forms UK Head Office

LightForms.com

8 Richfield Avenue Reading RG1 8EQ

+44 (0)20 8571 3785

Ε	London@
	LightForms.com