

Nova Medium 62 Trackspot

Installation / Maintenance Instructions

LIGHTFORMS






TS-00002

Precautions and Warnings

- •Read all instructions carefully, the safety of this product is only guaranteed if the instructions are followed, retain these instructions for future use.
- •Turn off the power suppler before installation and maintenance.
- •Installation must be carried out be a trained professional in accordance with all National electrical codes and regulations.
- •To avoid the risk of fire and overheating, make sure all connection, including those made by others, are correct and secure.
- •Do not pinch or apply excessive tension on the electrical wires. Damage due to improper handling and installation will void the warranty.
- •If any there is any damage to the product or the cable, the product must be returned to the retailer or manufacturer.





Luminaire Details

Power Supply:	230V AC 50Hz
IP Rating:	IP20
Class:	
Ta Max:	45°C

Fixing Method:	Track adaptor
Diameter:	62mm
Length:	170mm

Light FormsUK Head Office

LightForms.com

Unit 7C Boeing Way International Trading Estate Middlesex UB2 5LB T +44 (0)20 8571 3785

E London@ LightForms.com

Nova Small 62 Trackspot


Installation / Maintenance Instructions

LIGHT FORMS




Release locking tab.








Select the electrical circuit






In built driver

Insert into track. Note the orientation and guide pins.








In-Track driver

In-Track driver





Adjust.






Lock the fixture to the track.





Turn on power.



Light Forms UK Head Office

LightForms.com

Unit 7C Boeing Way International Trading Estate Middlesex UB2 5LB

+44 (0)20 8571 3785

E London@ LightForms.com